

**Declaration of performance  
No. DOP-1154-EN3-6-00099-12.17**

1. Unique code for the product type:

**7510, 7511**

2. Purpose of application or purposes of application intended by the manufacturer of the construction product in accordance with the applicable harmonised technical specification:

**Controlled closing of single- and double-leaf doors for  
fire/smoke resistance closures**

3. Name, registered brand name or registered brand and contact address of the manufacturer in accordance with Article 11, Paragraph 5:

**Allegion Netherland BV  
Energiestraat 2  
NL-3902 AV Veenendaal**

4. If appropriate, name and contact address of the authorised representative who is assigned to the tasks in accordance with Article 12, Paragraph 2:

**N/A**

5. Harmonised standard:

**EN 1154:1996/A1:2002/AC:2006**

6. Notified body:

The notified certification body for in-house production checks **no. 0432** has carried out the initial inspection of the manufacturing plant and factory production checks as well as the continuous monitoring, assessment and evaluation of the factory production checks and has issued the certificate of conformity of factory production checks (**to 0432-CPR-00099-12.17**).

**Notified product certification body no. 0432**

7. Declared performance:

Essential characteristics		Performance	Harmonised technical specification	
<b>Self-closing</b>				
5.2.1 General		Passed	EN 1154:1996/A1:2002/AC:2006	
5.2.3 Closing torque		Size 3-6: Passed		
5.2.4 Opening torque		Size 3-6: Passed		
5.2.5 Efficiency		Size 3-6: Passed		
5.2.6 Closing time		Passed		
5.2.7 Opening angle		Class 3: Passed (Frame fixing on the closing side) (7510) (Door leaf fixing on the closing side) (7511) Class 4: Passed (Door leaf fixing on the opening side) (7510) (Frame fixing on the opening side) (7511)		
5.2.8 Overload test		Passed		
5.2.9 Temperature dependence		Size 3-6: Passed		
5.2.10 Leakage		Size 3-6: Passed		
5.2.11 Damage		Size 3-6: Passed		
5.2.12 Latch regulation		Size 3-6: Passed		
5.2.13 Back check		Size 3-6: Passed		
5.2.14 Delayed action		Size 3-6: Passed		
5.2.15 Adjustable force		Size 3-6: Passed		
5.2.16 Play at zero point position		NPD		
5.2.18 Use on fire-/ smoke resistance doors		Class 1: For use on fire-/smoke resistance doors acc. to a test of EN 1634-1		
<b>Durability self-closing</b>				
5.2.2 Durability		Class 8: 500,000 cycles		
5.2.17.1 Corrosion resistance		Class 0: no requirements (with Gleitschiene RIII) Class 4: very high corrosion resistance (240 h)		
5.2.17.2 Corrosion resistance		Class 0: no requirements (with Gleitschiene RIII) Class 4: very high corrosion resistance (240 h)		
5.2.17.3 Corrosion resistance		Class 0: no requirements (with Gleitschiene RIII) Class 4: very high corrosion resistance (240 h)		
<b>Dangerous substances</b>				
ZA.3 Dangerous substances		The materials used in this product do not contain or release any dangerous substances.		

8. Suitable technical specification and/or specifical technical documentation:

N/A

The performance of the above products complies with the declared performances. The manufacturer mentioned above is solely responsible for drawing up the declaration of performance in accordance with Regulation (EU) no. 305/2011.

Remco Schijf, Managing QHSE of Allegion Netherland BV  
(Signatory Name and function in company)

AV Veenendaal, 08-08-2025  
(Place and date of issue)

\_\_\_\_\_  
(Signature)

